CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



CAL FIRE SINCE 105

LISTING No. 7170-0028:216 Page 1 of 2

CATEGORY: Control Unit (High-Rise)

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653

Contact: Larry Flood (203) 484-1200 FAX (203) 484-7309

DESIGN: Model NFS-640, NFS-640E fire alarm control units. Local, auxiliary, remote station (PPU),

proprietary (PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and

operational considerations. System components:

CPU-640, 640E CPU Board

NCA Network Communication Annunicator

NCM-W/F
LEM-320
Loop Expander Module
KDM-2
TM-4

Network Control Module
Loop Expander Module
Keyboard Display Module
Transmitter Module

CAB-4 Series Enclosure TR-A4, -B4, -C4, -D4 Trim Ring

DP-DISP Display Dress Panel

DP-1B Blank Panel
BMP-1 Blank Module
XPDP, DPDW-1B, DPSW-1B, VP-2B Dress Panels
CHS-4MB, -M2, -4L, -4N Chassis
NFS-LBB, BB-25, BB-17 Battery Box

NFS-LBB, BB-25, BB-17 Battery Box
BP-4 Battery Panel
STS-1 Security Tamper Swith

UDACT Universal DACT
UZC-256 Universal Zone Coder
ACM-8R, -16AT, -32A, 24AT, -48A Annunciator Control Module

AEM-16AT, AEM-32A, 24AT,-48A
AFM-16A, AFM-16AT, AFM-32A
AKS-1B
Annunciator Expander Modules
Annunciator Fixed Modules
Annunciator Key Switch

RPT-W, RPT-485W, RPT-485WF
RPT-F
*SCS-8
*SCE-8

Repeater Wire
Repeater Fiber
Smoke Control Station
Smoke Control Expander

*SCS-8L Smoke Control Lamp Driver Station *SCE-8L Smoke Control Expander Lamp

LCD-80 Liquid Crystal Display

LCD-80TM AnnunciatorTerminal Module LCD

LDM-32, -E32, -R32 Lamp Driver Module
RA400, -400Z, FDU-80 Remote Annunciators
FFT-7, -7S Fire Fighter's Telephone
FHS Fireman's Handset

FPJ Fireman's Phone Jack
RPJ-1 Remote Fireman's Phone Jack

VCM-4RK Voice Control Module
VCE-4 Voice Control Expander
ARM-4 Auxiliary Relay Module
AMG-1, -E Audio Message Generator

AA-30, -100, -120 Amplifiers

ABF-1B,-1DB,-2B,-2DB,-4B,-4DB
ABS-1TB, -2B
APS-6R/APS-6RE
Annunciator Enclosures
Annunciator Surface Box
Auxiliary Power supply

ACPS-2406 Addressable Power Supply & Battery Charger

CHG-120 Battery Charger

FCPS-24 Field Charger/Power Supply DCM-4RK Dual Channel Module CCM-1 Communication Module CRM-4RK Control Relay Module CRE-4 Control Relay Expander ICM-4RK Indicating Control Expander ICE-4 Indicating Circuit Expander

ISO-X Isolator Module XP5-M, XP5-C Transponder

XPIQ Transponder Quad Intelligent Audio XPC-8 Transponder Control Module XPM-8, XPM-8L Transponder Monitor Modules XPP-1 Transponder Processor

XPR-8 Transponder Relay Module PRN-5 Printer

VS4095 Keltron Remote Printer CRT-2 Display Terminal

ACT-1, -2 Audio Coupling Transformer

RM-1, RM-1SA Remote Microphone

NBG-12LX Addressable Manual Pull Station NBG-12LRA Agent Release Abort Station

FZM-1 Interface Module

REL-2.2K Releasing Supervision Kit

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units suitable for high rise applications for use with separately

listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

*Corrected 04-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 12, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division